

Central Hudson Gas & Electric Corporation
Local Transmission Plan

Assumptions
(as of October 1, 2009)

- Annual summer peak load growth rate for Central Hudson’s local transmission system = 0.76%.

Central Hudson Gas & Electric Peak Loads			
Year	Summer Peak	Year	Winter Peak
2004	1051	2004-05	988
2005	1204	2005-06	960
2006	1295	2006-07	934
2007	1185	2007-08	960
2008	1187	2008-09	911
2009	1107		
Forecast Peaks			
2009	1196	2009-10	No Winter Forecast
2010	1205	2010-11	
2011	1214	2011-12	
2012	1223	2012-13	
2013	1233	2013-14	
2014	1242	2014-15	
2015	1252	2015-16	
2016	1261	2016-17	
2017	1271	2017-18	
2018	1280	2018-19	
2019	1290	2019-20	

- No generation retirements within Central Hudson’s local transmission system.