

Central Hudson Battery Energy Storage Systems (BESS)

Charge and Discharge Schedules

Charge Window Permitted

- All year: 10pm-1pm

Charge	12am	1am	2am	3am	4am	5am	6am	7am	8am	9am	10am	11am	12pm	1pm	2pm	3pm	4pm	5pm	6pm	7pm	8pm	9pm	10pm	11pm
January																								
February																								
March																								
April																								
May																								
June																								
July																								
August																								
September																								
October																								
November																								
December																								

96	Charge not permitted
192	Charge permitted

Discharge Window Permitted

- All year: 7am-1am

Discharge	12am	1am	2am	3am	4am	5am	6am	7am	8am	9am	10am	11am	12pm	1pm	2pm	3pm	4pm	5pm	6pm	7pm	8pm	9pm	10pm	11pm
January																								
February																								
March																								
April																								
May																								
June																								
July																								
August																								
September																								
October																								
November																								
December																								

60	Discharge not permitted
228	Discharge permitted

VBER

Note: Compliance with charge/discharge schedule does not circumvent requirement to review and identify any potential BESS system impacts and infrastructure upgrades as part of system impact review under the NYSSIR process. In lieu of the charge/discharge schedule provided, BESS may opt to be studied under a 24/7/365 unrestricted schedule. The charge/discharge schedule applies to >50 kW standalone BESS, and hybrid systems that contain BESS, which will charge/discharge from the Central Hudson electric system.